



© DMITRY NAUMOV

Good Specs, Good Shop

Here's a way to help identify the types of motor-repair operations you really want to work with.

Greg Davison

Oklahoma Gas & Electric (OGE)

A good vibration specification is essential in accurately identifying a good motor repair and, for that matter, a good motor-repair shop. An operation consistently able to meet a good vibration spec has proven that it has a professional staff with the proper training and the precision equipment needed to make a quality repairs:

- It will have the test equipment and procedures in place for determining a scope of work resulting in a motor that meets the desired vibration specification.
- It will have a staff capable of accomplishing the required scope of work in a manner that will meet the desired vibration specification

and

- It will have test facilities capable of verifying that the motor does indeed meet the vibration acceptance criteria *before* leaving the shop.

The Oklahoma Gas & Electric (OGE) standard for allowable vibration on new or rebuilt Large Motors is 0.05 in. per second. The National Electrical Manufacturers Association (NEMA) standard for Medium and Large Motors with special requirements is 0.08 in. per second, (MGI-1993 rev1). (The OGE standard of 0.05 in. per second is approximately equivalent to the ISO G1.0 Balance Specification for special precision).

By specifying 0.05 in. per second as an acceptance standard, OGE is assured a motor has been balanced to the capability of most widely available balancing machines—and to the ability of most competent motor shops. Moreover, any mechanical fault or assembly error will result in a vibration level above the OGE specification. While it is extremely difficult to detect electrical faults in a motor that is operating under no-load conditions, the OGE specification leaves very little room for any type of fault-*electrical or mechanical*.

Win / win

Since OGE began using this spec, NO motor leaving a repair shop a having met the specification has been found upon commissioning to have a warrantable problem. The specification has been a win/win for both OGE and the shops.

- OGE receives a better product that lasts longer and eliminates delays during commissioning.
- The motor-repair shops have fewer motors returned for rework.

Reality check”

Experience has shown that the OGE specification is consistently achievable by well run repair facilities with the proper equipment and a professional work force. At least two such shops exist in Oklahoma City; both have agreed to meet this spec.

Whenever either of these shops receives an OGE motor for repair, a scope of work is agreed upon *before* the work

begins. If the motor is operable, a test runs may be used to establish an “as received” vibration reading on the motor shop’s test bed. Otherwise, the motor is disassembled and inspected for damage. A scope of work is developed to meet the OGE specification—and an OGE representative reviews the damage and the proposed scope of work,. The scope of work is either agreed to, or amended and agreed to.

The process works splendidly up until the point at which a motor fails the acceptance test. Then the fingers come out and the pointing begins. The scope of the work was modified, the motor shop claims it was not allowed to repair the unit properly. If, however, no scope is ever amended, cost creep occurs, and eventually the scope is seen as a blank check protecting the motor shop from any eventuality.

The reality is this: The scope of the work that the motor shop and the customer agreed to—in advance—is complete, but the motor will not meet the also-agreed to in advance vibration specification. Who pays? Is it the scope or the spec that's causing the problem?

The vibration specification can't be waived after the fact. That defeats the purpose of having one. Both the scope and the specs were agreed to in advance. If the scope is changed but the specification isn't, the motor shop agrees that the new scope is sufficient to meet the specification. If the shop cannot agree that the amended scope is adequate to meet the specification, then further negotiations may resolve the issues. Otherwise, the shop can be paid for its efforts thus far to produce the scope of work and the repairs can be let out for bid to competing motor repair shops.

The original shop may also decide to bid the repair in a way and at a price it feels will meet the original spec. After all bids are evaluated, the customer can go with the lowest bid or decide that meeting the specification is too costly. The customer might choose to replace the unit, or just decide to accept a degraded performance at a lower cost (in which case, the vibration specification could be modified). BUT whatever the decision is, it is always at the customer's discretion and agreed to in advance of any repairs.

To say that the scope of work is complete and the motor will not pass acceptance is unacceptable. Either the scope of work was insufficient to effect the proper repair or the acceptance criteria are too stringent. There is, of course, one other possibility. The scope was sufficient but improperly performed. This is the reason for the acceptance criteria in the first place—to ensure proper repair.

If the acceptance criteria are too stringent, is it safe to say that no motor would ever pass (or, at least, very few motors would pass)? Actually, the opposite is true. Most motors meet or exceed the vibration specification. Very few fail. This is further evidence that not only is the specification attainable, if is an effective way to identify a defective motor.

Separating wheat from Chaff

The OGE motor specifications will separate merely average repair shops from operations that are above average. One intent of our specification is to identify those shops that we want to do business with. OGE needs a good, quality repair to ensure the reliability of its generation assets. Shops that are capable of consistently meeting this specification are the quality shops OGE looks for.

Admittedly, the majority of motors failing the acceptance test are typically units that are inherently more difficult to repair—such as vertically mounted motors, two-pole motors and motors running above the first critical. Here again, the ability to effectively repair these difficult units is what separates the average from the above-average business.

To be sure, there is always the possibility the work might be done properly, but that the test facilities are inadequate. For example, the power supply might not be capable of running the motor full voltage, or the power supply might not be balanced across all three phases. In these cases, the ability to detect any type of electrically induced fault goes from being very difficult to impossible. On the other hand, the test bed might not be substantial enough to adequately support a motor as a rigidly mounted machine—in which case, the motor

has hardly any chance of meeting the specifications. Even if the shop has performed quality repair, without adequate testing facilities, there is no way of knowing the quality of the repair. Adequate testing facilities are one more hallmark of a quality motor repair shop. Don't overlook this important element.)

Remember this:

A good vibration spec will never replace an on-site inspection when identifying a quality motor-repair shop. Nor will it substitute for a certification from a standards organization such as NEMA. Over time, though, a good vibration specification CAN help your operations positively identify those shops that excel by routinely and consistently providing quality repairs (even when dealing with complex problems).

These are the shops OGE seeks—you should too. **MT**

Greg Davison is supervisor of Reliability Technologies with OGE Electric Services, a business of OGE Energy Corp. An ISO Category III Vibration Specialist with 27 years experience in the reliability and predictive maintenance fields. Greg Davison holds a B.S. in Organizational Management from Oklahoma Christian University. Telephone: 405-553-4463; Email: davisogd@oge.com davisogd@oge.com

Professional Staff ■ Proper Training ■ Precision Equipment

State-of-the-Art Testing



Meets EASA/ ANSI Standard SR 100-2010



MATLOCK

ELECTRIC MOTORS

Matlock Electric Company, Inc. 2780 Highland Avenue Cincinnati, OH 45212
513-731-9600 ■ 800-334-9548 service@matlockelectric.com

Customer Services

www.matlockelectric.com

AC ELECTRIC MOTOR

REWINDING AND REMANUFACTURING

- Single Phase Motors
- 3 Phase Motors up to 15,000 HP
- High Voltage 3 Phase Motors
- Hermetic Stators
- Wound Rotors
- AC Alternators
- Variable Speed Commutator Motors
- U.L. Rebuilding Cert.# E189767
- Specialty Motors Manufactured to Cust. Specs.

DC ELECTRIC MOTOR AND GENERATOR

REWINDING AND REMANUFACTURING

- DC Motors up to 10,000 HP
- Armature Rewinding
- DC Welders, Rotating and Static
- DC Lifting Magnets
- Elevator Shunt Fields
- Elevator Lift Motor Fields

ELECTRICAL APPARATUS SALES

- New Single Phase AC Motors
- New Three Phase AC Motors up to 15,000 HP
- Remanufactured Three Phase AC Motors up to 30,000 HP
- New DC Motors
- Remanufactured DC Motors up to 12,000 HP
- New Transformers
- Remanufactured Transformers up to 500 MVA
- Gear Motors and Speed Reducers
- AC Variable Frequency Drives
- Fuses
- Surge Suppressors
- DC Drives
- Generators
- Rectifiers
- Resistors
- Rheostats
- Hoists
- Electric Motor Controls
- Brakes
- Pumps
- Power Factor Capacitors
- Renewal Parts

ON SITE

- PdMA... MCE/ MCA Testing
- Elevator Lift Motor Rewinding
- Rewinding
- Lasar Alignment
- Vibration Analysis
- Electrical Trouble Shooting Repair
- Mechanical Trouble Shooting Repair
- Electric Motor Removal and Installation

MECHANICAL SERVICING

- Computerized Dynamic Balancing
- General Machine Shop Services
- Hermetic Compressors
- Metal Restorations and Finishing
- Pump Repair
- Rotor Rebaring and Repair
- Fan Repair and Remanufacturing
- Gearhead Repair and Remanufacturing
- Welding TIG, MIG, Heliarc
- Abrasive Blasting
- Cleaning-Steam, Caustic & Heat Stripping
- Vibration Analysis
- Lasar Alignment
- Shop Fabrication
- Rebabbing Bearing Service
- Metalizing

ELECTRIC/ ELECTRONIC SERVICING

- Electromechanical Servicing
- AC VFD DC Drives Servicing
- Printed Circuit Board Repair
- Custom Panel Fabrication
- Power Factor Surveys
- Welder Repair and Rebuilding
- Infrared Testing (Thermal Imaging)
- Acoustical Analysis
- Voltage Wave Form Testing
- Harmonic Testing
- Ultrasonic Testing
- PdMA. MCE/ MCA Testing
- Servo Motor Rebuilding
- Elevator Lift Motor Rewinding

SPECIALTY PRODUCTS AND SERVICES

- Inpro Isolators
- Carbon Brushes
- Babbit Bearings
- VPI Capacity 8 ft.
- Core Testing
- No Load Testing up to 7,000 HP
- Load Testing up to 900 HP
- Baker Surge Testing
- Manufacture Custom Design, Specialty Coils
- PdMA . MCE/ MCA Testing
- DLI Vibration Analysis
- Infrared Testing (Thermal Imaging)

TRANSFORMER SERVICING

- Air Cooled Rewinding and Rebuilding
- Oil Filled Rewinding and Rebuilding
- Welder Transformer Rebuilding
- Auto Transformer Rewinding

CUSTOMER ADVANTAGE PROGRAM

- Advantage Exchange
- Customer Motor Inventory Programs
- Plant Asset Management Services